

## **SOUTH GIPPSLAND WATER DUMP POINT INSTALLATION GUIDELINES**

Information provided by South Gippsland relating to installation of dump points is outline below, please note this information is provided on a case by case basis:

- Written request is required from the Committee outlining who will be responsible for cost, management and maintenance of the dump point, preferably on letterhead.
- The request needs to provide clarity around who will install, operate and maintain the dump point.
- A plan outlining the proposed location and design information of the dump point is required.
- Intention to charge for the use of the dump point.
- No Changes to be made to dump point unless approved by South Gippsland Water
- Letter of support/permission from the land owner and/or Council to install the dump point.
- Additional water usage and cistern charge incurred by the installation of the dump point and its ongoing use, are to be met by the Committee.
- The dump point is to be securely locked at all times. Adequate signage is to be placed at the site advising users of how or whom they need to contact to use the facility.
- A record of user activity is to be kept and supplied to South Gippsland Water on request.
- The dump point is not to be used for trade waste purposes or by any commercial operators.
- The dump point is to be connected to the existing internal sewer system
- The water supply to the dump point is to be fitted with a testable backflow prevention device (RPZD) at the existing water meter (or new tapping required if not already tapped)
- Prior to works commencing, the "Application to Connect to Water and Sewer" is to be completed and submitted to South Gippsland Water, together with the appropriate fees.
- "As constructed" details are to be provided to South Gippsland Water in accordance with Plumbing Industry requirements.
- South Gippsland Water will carry out random audits of this facility.
- If at any time South Gippsland Water considers that the dump point is not being operated in accordance with these conditions, its operation will be reassessed and South Gippsland Water reserves the right to request its removal.

